

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Annual Periodical Renewal Fire Certificate

From
 Regional Fire Officer
 Andhra Pradesh, Vijayawada

To:
 The District Educational Officer,
 Chittoor District

File No: 17141 (I.R.RFO/2021, Date:10/03/2021
 Occupancy No: RC Number: 182/RFO/SR/2020

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Annual Periodical Fire Certificate to the constructed Non Multi Storeyed Building of **M/s Veritas Sainik E.M School, represented by B.Srikar Reddy, C.Ramapuram, Tirupathi, Chittoor District** - Regarding.

- Ref: 1 G.O.Ms.NO.71 Home (Prisons-A) Department, Dated:01-04-2010 & G.O.Ms.NO.140 Home/Prison & Fire Services) Department, Dt:04-09-2015.
- 2 This Office Delegation of Powers Rc No.3350/Audiv/NOC/2012, Dated:09-03-2017.
- 3 This Office NOC for Occupancy Rc No. 182/RFO/SR/2020, Dt. 17/07/2020
- 4 Renewal NOC For Occupancy 182/RFO/SR/2020, Dt. 17/07/2020
- 5 Online Application for Renewal NOC of B.Srikar Reddy, C.Ramapuram, Tirupathi, Chittoor District - Inspection report called for Regarding.
- 6 Online Inspection Report submitted by Officers of this Department on 09-03-2021.


<< 0 >>


The Management of **M/s Veritas Sainik E.M School**, represented by **B.Srikar Reddy, C.Ramapuram, Tirupathi, Chittoor District** has requested to issue Annual Periodical Fire Certificate for period 2017-2018 duly remitting the Fire Precautionary fee for Rs 48520/- vide challan No. 41404104512020, Dated 02/03/2021 at SBI, S.V.U Campus, Tirupathi.

M/s Veritas Sainik E.M School

- This certificate is being issued as per G.O.Ms.No 140 Home (prisons & Fire Services) Department, Dt: 04.09.2015.
- The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Annual Periodical Renewal Fire Certificate for vide reference 4th cited to the constructed Non Multi Storeyed Building.
- The Officers of the department have recommended to issue The Annual Periodical Renewal Fire Certificate **B.Srikar Reddy C.Ramapuram, Tirupathi, Chittoor District**, subject to the following conditions.

As Builder	As Occupant	As Security Personnel
<p>All the fire protection arrangements shall be maintained in good condition as seen during inspection</p> <p>Any loss of life or property due to non functioning of fire safety measures and other installations shall be the responsibilities of the management.</p> <p>Addition / alteration, if any in the building may be verified by building authority</p>	<p>All the escape/exit routes shall not be kept locked/blocked or encroached</p> <p>All occupants shall be trained to operate the fire safety equipments during emergency</p> <p>Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.</p>	<p>All the occupants must know the correct method of operation of the fire fighting system installed.</p> <p>Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.</p> <p>All security personnel shall be trained to operate the fire safety equipments during emergency</p>


PRINCIPAL
VERITAS SAINIK SCHOOL
C. RAMAPURAM, TIRUPATI
Chittoor (Dt.), A.P., 517 561.


MANAGER
VERITAS SAINIK SCHOOL
C. RAMAPURAM, TIRUPATI
Chittoor (Dt.), A.P., 517 561.

<p>This is Only for Fire Safety Point of View</p>	<p>Raise the alarm if the fire cannot be controlled. Evacuate the area completely at once with nearest safe exit</p>	<p>Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.</p>
---------------------------------------------------	----------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------

4. This Annual Periodical Renewal Fire Certificate is valid from 17/03/2021 to 16/03/2026.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006


The following deficiencies are identified by the officers of the department and needs to be attended to by the management.
Conditions :

- ☒ This Renewal NOC is issued from Fire Safety Point of view only basing status of Building only and this Renewal NOC is not for claiming proprietary or ownership rights. Further, in case of any deviation noticed with respect to this Renewal NOC after issuance of this Renewal NOC, the same Renewal NOC shall be liable for cancellation at any time. The Management has to rectify the deficits within six months as per affidavit submitted.
- ☒ The Management has to maintain Fire Safety Measures and other installations in good working condition at all times and the Responsibility of Fire Fighting equipment maintenance lies with the management as seen & tested by the committee at the time of inspection.
- ☒ The life safety and neighbor safety risk to be borne by the Management only. This Certificate covers Fire Safety Equipment installation as per NBC-2106. The legal issue in respect of life safety doesn't cover under this Certificate. The Management is responsible for all risks involved in case of Fire Accident in the Building
- ☒ This Renewal NOC is valid for (05) years only and It is the responsibility of the Builder/Owner to apply for renewal of No Objection certificate, duly remitting the user charges as per G.O.Ms.No.140, Home (Prisons & Fire Service) Department.Dt.04-09-2015, two months before expire of this No Objection Certificate and shall provide the deficit firefighting equipment as per NBC within (06) months



17141/CTR/RF0/2021

Your Sincerely,


Regional Fire Officer

Andhra Pradesh, Vijayawada

Copy to B Srikar Reddy, M/s Veritas Sainik E.M School, C.Ramapuram, Tirupathi, Chittoor District

Copy to Chief Officer for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned


PRINCIPAL

VERITAS SAINIK SCHOOL
C. RAMAPURAM, TIRUPATI
Chittoor (Dt.), A.P., 517 561.


MANAGER

VERITAS SAINIK SCHOOL
C. RAMAPURAM, TIRUPATI
Chittoor (Dt.), A.P., 517 561.